



**SALEM FIRE DEPARTMENT  
BUREAU OF FIRE PREVENTION  
152 MAIN STREET**

**SALEM, NEW HAMPSHIRE 03079**

**BUSINESS: (603) 890-2200 FAX: (603) 893-3789**

**JEFFREY S. EMANUELSON, CFI  
FIRE MARSHAL**

**THOMAS MUISE  
FIRE INSPECTOR**

## **GENERAL PRECAUTIONS AGAINST FIRE**

### **International Fire Code 2000 edition**

#### **Chapter 3 Section 307.5**

**Open Flame Cooking Devices.** Charcoal burners and other open flame cooking devices including electric grills shall not be operated on combustible balconies or within 10 feet of combustible construction.

#### **Chapter 3 Section 307.5.1**

**Liquified Petroleum – gas – fueled cooking devices.** LP gas burners shall not be located on combustible balconies or within 10 feet or combustible construction.